

Annexure - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO...12.12

Dated...15.07.2025

It is certified that an inspection team headed by Praveen Kumar, JE (Name of Officers with designation) From Dighalbank. PHED inspected the **Milli Girls School, Talimabad, Tappu, Tarabari chowk, Dighalbank, Dist-Kishanganj, Bihar** (Name & Address of the School) on 11.07.2025 (date of inspection) and on the basis of Water Test Report Attached bearing no...12.12 dated-15.07.2025 of District Level Water Testing Laboratory under P.H. Division Kishanganj Certified that the **Milli Girls School** (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till One Year.

Praveen Kumar
JE Dighalbank
11/07/2025

15/07/25
Signature with seal:
Executive Engineer
P.H. Division Kishanganj

Designation :- Executive Engineer

Name & Address of the Office/Department :- Public Health Division, Kishanganj

To,

**Milli Girls School, Talimabad, Tappu,
Tarabari chowk, Dighalbank,
Dist-Kishanganj (Bihar)**
(Name & Address of the Institution)

Note :- The certificate is to be issued by authorized officer/PHED Lab/local bodies.



DISTRICT LEVEL WATER TESTING LABORATORY
UNDER

P.H. DIVISION KISHANGANJ

Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj

Sample Collected By: - School Staff						Date of Sample Submitted in Lab :- 10.07.2025							
District - Kishanganj						Date of Reporting :- 12.07.2025							
Sl.No	Block	Location	Turb.	PH	Fe	TH	Alkalinity	Ca	Mg	Cl	Cond.	T.D.S	Remark
1	Dighalbank	Milli Girls School, Talimabad, Tappu, P.O- Tarabari chowk, Dighalbank, Pin- 855108 Dist- Kishanganj	1.04	6.95	0.48	63.36	61.2	15.84	5.77	11.82	156	101	
			Desirable limit	1 NTU	6.5-8.5	1.0 mg/l	200 mg/l	75mg/l	30mg/l	250mg/l	500 mg/l	
			permissible Limit *in absence of alternate source IS:10500 :2012	5 NTU	NR	600 mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	μ mhos/cm	2000 mg/l	

NR- No Relaxation

Sgtiv
12/07/25
Lab. Assistant
P.H. Division Kishanganj

Sgtiv
12/07/25
Chemist
P.H. Division Kishanganj

Sgtiv
12/07/25
Assistant Engineer
P.H. Sub Division Kishanganj

